

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 411

Dated : 24/6/2026

It is certified that an inspection team headed by Mohit Gupta (Sub Engineer) from Nagar Palika Parishad Bhind PHED inspected the Scholars Public School Yadunath Nagar Bhind on and on the basis of water test report (Attached) bearing no 56112 dated 23-6-26 of Nagar Palika Parishad Bhind (PHED Lab) certified that the Scholars Public School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 5 years

Signature with seal

Name

Designation

Name & Address of the Office/Department R.H.P.

To

✓ The Principal
Scholars Public School
Yadunath Nagar
Bhind (M.P.) 477001

Note : The certificate is to be issued by authorized officer/PHED Lab/local bodies

Manager

Scholars Public School
Yadunath Nagar, Bhind (M.P.)
School Code-50675

Principal
Scholars Public School
Yadunath Nagar, Bhind (M.P.)
School Code-50675



DISTRICT LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
SUB. DIVISION - BHIND (M.P.)

- | | |
|--------------------------|--|
| 1. Sample From | Shri.Dharmendra Singh Kushwaha |
| 2. Particulars of Sample | Scholar Public School Yadunath Nagar Bhind |
| 3. Date of Collection | 22/06/2026 |
| 4. Date of Analysis | 23/06/2026 |

S. No.	Characteristics	Unit	As per BIS- 10500-2012 For Drinking Water		Result				
			Requirement Desirable Value	Permissible limit in the absence of Alternate Source					
PHYSICAL					Sample-1	Sample-2	Sample-3	Sample-4	Sample-5
1	Turbidity	NTU	1.0	5.0	0.0				
2	Colour	Hazen	5	15	Nil				
3	Taste & Odour		Un Objectionable	Un Objectionable	Agreeable				
4	Temperature	C°	-	-	22.c				
CHEMICAL									
5	Ph Value	pH Scale	6.5 to 8.5	No Relaxation	7.0				
6	Alkalinity	Mg/L	200	600	95				
7	Chlorides (as Cl)	Mg/L	250	1000	12.4				
8	Nitrate as No 3	Mg/L	45	45	0.0				
9	Total hardness by standard E.D.T.A. Solution	Mg/L	200	600	42				
10	Calcium as Ca	Mg/L	75	200	10.4				
11	Magnesium as mg	Mg/L	30	100	3.8				
12	Iron	Mg/L	1.0	1.0	0.0				
13	Free Chlorine	Mg/L	0.2	1.0	Nil				
14	T.D.S.	Mg/L	500	2000	142				
15	Fluoride	Mg/L	1.0	1.5	0.0				
16	Arsenic	Mg/L	0.01	0.1	...				
17	Sulphate	Mg/L	200	400	...				
18	Bactological Feacu Coliform	Per 100 ml.	0	0	Nil				


Chemist
Water Testing Lab
P.H.E. Division - Bhind


Assistant Engineer
Public Health Engineering
Sub Division - Bhind (M.P.)


Manager
Scholars Public School
Yadunath Nagar, Bhind (M.P.)
School Code-50675


Principal
Scholars Public School
Yadunath Nagar, Bhind (M.P.)
School Code-50675